



ENGINEERING DEPARTMENT
Civil/Traffic/Parking/Signal & Lighting/Sign & Pavement Marking
Daniel J. Moeglin, P.E., S.I., City Engineer
2436 30th St. NE/Canton OH 44705
PH 330 - 489-6900 / FAX 330 - 489-3337

July 28, 2010

ADDENDUM #2

TO: PROSPECTIVE BIDDERS

RE: GUILFORD AVE. NW BRIDGE REPLACEMENT, GP 1075

The attention of all Bidders on the above project, bids which shall be taken on July 29, 2010 are called to this Addendum # 2

Make the following corrections to the Plans:

Page 4/38 **Delete:** "For new water mains within the city, all water main pipe materials, fittings, bends, valves, valve boxes, megalugs, gaskets and hydrants will be supplied by the City of Canton. The contractor will be responsible for transporting materials to the project site." This note is not intended to be part of this contract. The contractor will be responsible to purchase, supply and install the waterworks items as part of this plan.

Page 16/38 **Clarification:** The DRILLED SHAFTS, 42" DIAMETER, INTO BEDROCK includes 15' socket in the bedrock. Note that the rebar gage layout and diameter is different from the rebar layout and diameter above the socket. The bidder must include this as part of the bid for the 524 Item. There is no separate item for the socket.

Page 17/38 **Clarification:** Detail SECTION D-D shows a Precast Concrete Headwall. The supplier of the CONDUIT, TYPE A, PRECAST REINFORCED CONCRETE ARCH SECTIONS (36' SPAN x 11' RISE) may, or may not, possibly include the Precast Concrete Headwall as a detached section. Whether the section is attached or not, the cost of the headwall and installation shall be incidental and inclusive of the 603 bid item.

Page 13/38 and 17/38 **Clarification:** Under Notes 1. USE DAYTON/ RICHMOND FORM LINER STONE PATTERN NUMBER 1538, OR APPROVED SIMILAR. The intent of this item is to provide a pattern similar to Ashlar Stone or sometimes referred to as, "dressed stone." The Earth Tone Color, as approved by the Engineer is a concrete stain and not a tinting of the epoxy sealer. This stain is incidental to the Class C Concrete.

Please sign this Addendum No. 1 at the bottom of this page as proof of receipt and **RETURN
SAME WITH YOUR BID.**

Thank you for your cooperation in this matter.

Respectfully,

Steven L. Henderson
Canton City Engineering Construction Manager

BIDDERS AUTHORIZED SIGNATURE DATE

NAME / TITLE (Printed or Typed)