



To: All Plan Holders of Record

From: CT Consultants, Inc.

Re: Addendum No. 1
City of Canton Water Reclamation Facility
Phosphorus/Total Nitrogen Project Contract No. 26

Date: November 26, 2013

This Addendum forms a part of the contract documents and modifies the original bidding documents dated November 2013. Acknowledge receipt of this addendum in the space provided on the "bid form." Failure to do so may subject the bidder to disqualification.

VOLUME 1

Table of Contents

- Page iii - **ADD** the following Pages to Volume 1 after DBE Form 2. (Forms are included in Attachment A).

	Page No.
Violating Facilities	SR EPA -2
WPCLF Payments	SR EPA -3
WPCLF Contract Change Order	SR EPA -4
Continuous Treatment Provisions	SR EPA -5

- Page vii – 8. Analytical Report from Alloway (Mudwell-Center Wall Sample **ADD** Grit – SW Tank and Incinerator #2 Ash Hearth #6)

Owner Contractor Agreement

- Page OCA-2 – **REPLACE** “8. Analytical Report...” with the following:
8. Analytical Report from Alloway, for “Mudwell – Center Well Sample No. L12-10280-01, Grit – SW Tank Sample No. L12-10281-01, Incinerator #2 Ash Hearth #6 Sample No. L12-11645-01”, dated January 26, 2012 or March 7, 2012, consisting of 5 pages.

VOLUME 2

Specification 01010 – Summary of Work

- Page 30 - **CHANGE** 2013 to 2014. The Owner is required to stop using the incinerators on December 31, 2014.
- Page 37 - **REPLACE** “8. Analytical Report...” with the following:
8. Analytical Report from Alloway, for “Mudwell – Center Well Sample No. L12-10280-01, Grit – SW Tank Sample No. L12-10281-01, Incinerator #2 Ash Hearth #6 Sample No. L12-11645-01”, dated January 26, 2012 or March 7, 2012, consisting of 5 pages.

VOLUME 3

No changes in this Addendum.

APPENDIX

Section 8

- **REPLACE** “8. Analytical Report...” with the following:
8. Analytical Report from Alloway, for “*Mudwell – Center Well Sample No. L12-10280-01, Grit – SW Tank Sample No. L12-10281-01, Incinerator #2 Ash Hearth #6 Sample No. L12-11645-01*”, dated January 26, 2012 or March 7, 2012, consisting of 5 pages.
- **ADD** the Analytical Report from Alloway consisting of three (3) pages. The report is included in Attachment B.

PLANS

The following plan sheets are **REVISED** per the notes below:

- | | | |
|----------|-------|---|
| Sheet 67 | 3P-01 | <u>DELETE</u> references to Section Cuts Q, R, and S and refer to Sheets 4D-06 and 4P-07 for Tunnel E details. |
| Sheet 78 | 3P-12 | <u>DELETE</u> references to Section Cuts Q, R, and S and refer to Sheets 4D-06 and 4P-07 for Tunnel E details. |

PRE-BID MEETING MINUTES

Attachment C includes Minutes of the Pre-Bid Meeting held on November 22, 2013. The Minutes of the Pre-Bid Meeting shall be made a part of this Addendum.

A copy of the presentations provided at the meeting will be available on CT Consultant’s website: <http://www.ctconsultants.com/bidinfo/10182/>.

AGW/saa

Enclosures

ATTACHMENT A

Violating Facilities:

The Contractor agrees to comply with all applicable standard, orders or requirements under Section 306 of the Clean Air Act, 42 USC 1857 (h), Section 508 of the Clean Water Act, 33 USC 1368, Executive Order 11738, and EPA regulations, 40 CFR Part 32, which prohibits the use under non-exempt Federal contracts, grants, or loans of facilities included on the EPA List of Violating Facilities.

WPCLF Payments:

This project is funded in whole or in part by funds from the Water Pollution Control Loan Fund (WPCLF) as administered by the Ohio EPA-DEFA and the Ohio Water Development Authority (OWDA). The Contractor shall comply with all requirements of these programs. The Owner shall be responsible for the progress payments to the contractor if the Owner becomes ineligible for further payments due to circumstances which are of no fault of the contractor. The monthly payments to vendors may be made through the Owner, the OWDA, or both as deemed by the Owner.

The time frame for payment of pay estimates by the Owner and/or Special Funding Agency(s) may be up to 40 calendar days from date of receipt of pay estimate from engineer to Owner.

Ohio EPA/DEFA must approve all change orders before the change order may be submitted for payment on a pay estimate.

**STATE OF OHIO
WATER POLLUTION CONTROL LOAN FUND
CONTRACT CHANGE ORDER**

RECIPIENT: _____
 WPCLF LOAN NO.: _____
 OWDA LOAN NO.: _____

CHANGE ORDER NO.: _____
 CONTRACT: _____
 DATE: _____

DESCRIPTION OF CHANGE:

TOTAL _____ \$0.00

RECOMMENDED BY: _____
 CT CONSULTANTS

APPROVED BY: _____
 CITY/COUNTY OFFICAL

ACCEPTED BY: _____
 COMPANY

DATE: _____
 DATE: _____
 DATE: _____

	AWARDED CONTRACT AMOUNT	WPCLF LOAN LINE ITEM AMOUNT
Original Amount	_____	_____
Previous Changes (+/-)	_____	_____
This Change (+/-)	_____	_____
Adjusted Amount	_____	_____

(OWDA APPROVAL)

The above proposal is hereby accepted and I recommend that it be approved and made a part of the contract covered by OWDA Project No.

Chief Engineer _____ Date _____

Executive Director _____ Date _____

(OHIO EPA ACCEPTANCE)

Ohio EPA ACCEPTANCE _____ Date _____

Continuous Treatment Provisions:

1. Federal regulations prohibit bypassing of any sewage during construction operations. The contractor will be responsible for providing any required temporary pumping facilities piping, etc., necessary to complete the project without any plan bypassing and continuous treatment must be provided at the same level during construction as existed prior to construction.
2. Unless otherwise previously or subsequently specified, the Contractor shall procure and pay for all permits, licenses, and approvals necessary for the execution of this Contract.
3. The Contractor shall comply with all laws, ordinances, rules, orders, and regulations relating to the performance of the work required to complete this Contract.

ATTACHMENT B



ANALYTICAL REPORT

Canton, City of
 Attn: Kelly Berta
 3530 Central Avenue SE
 Canton, OH 44707

Lab Project # L12-10281
 Received: 01/10/2012
 Reported: 01/26/2012
 Date/Time Sampled: 01/06/2012 08:35
 Sampled By: R/S
 Sampled Matrix: Solid
 Containers: 3

Project Name: Waste Profile - Grit

Sample ID: Grit - SW Tank
 Lab Sample # L12-10281-01

Analyte	Results	Units	PQL	Method	Analyst	Extraction Date	Analysis Date
Paint Filter	pass	Y/N		SW-9095	KG		01/11/2012
Arsenic, TCLP	<0.50	mg/L	0.50	SW-6010	AB		01/23/2012
Barium, TCLP	0.31	mg/L	0.10	SW-6010	AB		01/23/2012
Cadmium, TCLP	<0.10	mg/L	0.10	SW-6010	AB		01/23/2012
Chromium, TCLP	<0.10	mg/L	0.10	SW-6010	AB		01/23/2012
Lead, TCLP	<0.10	mg/L	0.10	SW-6010	AB		01/23/2012
Selenium, TCLP	<0.50	mg/L	0.50	SW-6010	AB		01/23/2012
Silver, TCLP	<0.10	mg/L	0.10	SW-6010	AB		01/23/2012
Mercury, TCLP	<0.020	mg/L	0.020	SW-7471A	LW		01/18/2012
o-Cresol (2-methylphenol), TCLP	<0.50	mg/L	0.50	SW-8270C	LW	01/13/2012	01/16/2012
m&p-Cresol (3&4-methylphenol), TCLP	<1.00	mg/L	1.00	SW-8270C	LW	01/13/2012	01/16/2012
Pentachlorophenol, TCLP	<0.50	mg/L	0.50	SW-8270C	LW	01/13/2012	01/16/2012
2,4,5-Trichlorophenol, TCLP	<0.50	mg/L	0.50	SW-8270C	LW	01/13/2012	01/16/2012
2,4,6-Trichlorophenol, TCLP	<0.50	mg/L	0.50	SW-8270C	LW	01/13/2012	01/16/2012
2,4-Dinitrotoluene, TCLP	<0.10	mg/L	0.10	SW-8270C	LW	01/13/2012	01/16/2012
Hexachlorobutadiene, TCLP	<0.10	mg/L	0.10	SW-8270C	LW	01/13/2012	01/16/2012
Hexachlorobenzene, TCLP	<0.10	mg/L	0.10	SW-8270C	LW	01/13/2012	01/16/2012
Hexachloroethane, TCLP	<0.10	mg/L	0.10	SW-8270C	LW	01/13/2012	01/16/2012
Nitrobenzene, TCLP	<0.10	mg/L	0.10	SW-8270C	LW	01/13/2012	01/16/2012
Pyridine, TCLP	<1.00	mg/L	1.00	SW-8270C	LW	01/13/2012	01/16/2012
1,4-Dichlorobenzene, TCLP	<0.10	mg/L	0.10	SW-8270C	LW	01/13/2012	01/16/2012
(Surrogate) 2-Fluorophenol	75.3 (22.5-98.5)	%		SW-8270C	LW	01/13/2012	01/16/2012
(Surrogate) Phenol d6	75.3 (21.7-100.1)	%		SW-8270C	LW	01/13/2012	01/16/2012

Analysis Certified By: *Radoslaw Polek*

1101 N. Cole Street - Lima, Ohio 45805
 419.223.1362 - Fax 419.227.3782
 800.436.1243

508 Bissman Ct. - Mansfield, Ohio 44903
 419.525.1644 - Fax 419.524.5575
 800.635.3222

1776 Marion-Walco Rd. - Marion, Ohio 43302
 740.389.5991 - Fax 740.389.1461
 800.873.2835

ANALYTICAL REPORT

 Canton, City of
 Attn: Kelly Berta
 3530 Central Avenue SE
 Canton, OH 44707

 Lab Project # L12-10281
 Received: 01/10/2012
 Reported: 01/26/2012
 Date/Time Sampled: 01/08/2012 08:35
 Sampled By: R/S
 Sampled Matrix: Solid
 Containers: 3

Project Name: Waste Profile - Grit

 Sample ID: Grit - SW Tank
 Lab Sample # L12-10281-01

Analyte	Results	Units	PQL	Method	Analyst	Extraction Date	Analysis Date
(Surrogate) Nitrobenzene d5	65.4 (6.3-125.0)	%		SW-8270C	LW	01/13/2012	01/16/2012
(Surrogate) 2-Fluorobiphenyl	68.1 (34.8-102.1)	%		SW-8270C	LW	01/13/2012	01/16/2012
(Surrogate) 2,4,6-Tribromophenol	57.4 (14.2-121.6)	%		SW-8270C	LW	01/13/2012	01/16/2012
(Surrogate) p-Terphenyl-d14	65.6 (37.2-96.0)	%		SW-8270C	LW	01/13/2012	01/16/2012
Benzene, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
Carbon Tetrachloride, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
Chlorobenzene, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
Chloroform, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
1,2-Dichloroethane, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
1,1-Dichloroethene, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
Methyl Ethyl Ketone (2-Butanone), TCLP	<1.00	mg/L	1.00	SW-8260B	MS		01/13/2012
Tetrachloroethene, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
Trichloroethene, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
Vinyl Chloride, TCLP	<0.05	mg/L	0.05	SW-8260B	MS		01/13/2012
(Surrogate) 1,2-Dichloroethane d4	88.6 (53.6-137.7)	%		SW-8260B	MS		01/13/2012
(Surrogate) Toluene d8	97.3 (69.7-120.9)	%		SW-8260B	MS		01/13/2012
(Surrogate) 4-Bromofluorobenzene	89.2 (31.3-173.6)	%		SW-8260B	MS		01/13/2012
TCLP extraction	*	Y/N		SW-1311	CAM		01/12/2012
Zero Headspace TCLP Extraction	*	Y/N		SW-1311	MS		01/12/2012

Analysis Certified By:



 1101 N. Cole Street - Lima, Ohio 45805
 419.223.1362 - Fax 419.227.3792
 800.436.1243

 508 Bissman Ct. - Mansfield, Ohio 44903
 419.525.1644 - Fax 419.524.5575
 800.635.3222

 1776 Marion-Waldo Rd. - Marion, Ohio 43302
 740.389.5991 - Fax 740.389.1481
 800.873.2835



ANALYTICAL REPORT

Canton, City of
Attn: Kelly Berta
3530 Central Avenue SE
Canton, OH 44707

Lab Project # L12-11645
Received: 02/28/2012
Reported: 03/07/2012
Date/Time Sampled: 02/28/2012 08:15
Sampled By: Kneffler
Sampled Matrix: Solid
Containers: 1

Project Name: Incinerator #2

Sample ID: Ash Hearth #6
Lab Sample # L12-11645-01

Analyte	Results	Units	PQL	Method	Analyst	Extraction Date	Analysis Date
Arsenic, TCLP	<0.50	mg/L	0.50	SW-6010	MBU		03/05/2012
Barium, TCLP	0.22	mg/L	0.10	SW-6010	MBU		03/05/2012
Cadmium, TCLP	<0.10	mg/L	0.10	SW-6010	MBU		03/05/2012
Chromium, TCLP	<0.10	mg/L	0.10	SW-6010	MBU		03/05/2012
Lead, TCLP	<0.10	mg/L	0.10	SW-6010	MBU		03/05/2012
Selenium, TCLP	<0.50	mg/L	0.50	SW-6010	MBU		03/05/2012
Silver, TCLP	<0.10	mg/L	0.10	SW-6010	MBU		03/05/2012
Mercury, TCLP	<0.020	mg/L	0.020	SW-7470A	LO		03/06/2012
TCLP extraction	*	Y/N		SW-1311	CAM		03/01/2012

Analysis Certified By: _____

Lane Jackson

ATTACHMENT C

Meeting Summary

To: Attendees and Plan Holders

Subject: *City of Canton Water Reclamation Facility
Phosphorus/Total Nitrogen Project Contract No. 26
Pre-Bid Meeting*

Date: November 26, 2013

A Pre-bid Meeting was held on November 22, 2013 at 10:00 a.m. EST at the City of Canton Water Reclamation Facility: 3530 Central Ave. SE, Canton, OH 44707. Highlights of the meeting follow.

WELCOME & GENERAL INTRODUCTION

- Project Partners were introduced
- Bid Documents
 - Bid Documents include Plans, 3 Volume Project Manual, Appendix
 - Contractors were encouraged to submit RFIs – In Writing Only to:

Ashley Williston
CT Consultants, Inc.
awilliston@ctconsultants.com
Fax: (440)-951-7487

- This includes questions specific to OVIVO.
- Bids Due **2:00 P.M. EST December 31, 2013**, Purchasing Department
218 Cleveland Avenue, SW, Sixth Floor, Canton, OH 44702
 - The reasoning for the selected date is to maximize the amount of time from scheduled Load Award Meeting for Contractors to comply with Sludge Load-Out Facility substantial completion of December 1, 2014 and accommodate OEPA's requirement that all loan documents be submitted 45 days prior to Loan Award Meeting.

PROJECT OVERVIEW

- General Scope
 - Convert Conventional Activated Sludge Plant to a Membrane Bioreactor (MBR)
 - Replace Preliminary Treatment
 - Convert Existing Clarifiers to Equalization
 - Change Solids Handling
 - Replace SCADA
 - Other Improvements
- MBR System Furnished by OVIVO in Separate Procurement Agreement ~ \$29 mil.
 - Contractor's must become familiar with Scope of Supply – See Appendix
 - Contractor is Third Party Beneficiary
 - Coordination and Communication are Critical Regarding Interrelated Equipment Systems - Fabrication, Shipping, Storage, Installation, Start-Up and Commissioning
- Single Prime Contract for the Balance of the Work - \$50 mil. Construction Cost Opinion
- Phasing/Sequencing are Critical to Keep Facility Operational at all times – See Spec Item 01010 – Summary of Work
- Warranty periods for equipment shall begin after issuing substantial completion certificates for the respective equipment.
- The Contractor shall include a fee of \$7,000.00 in their bid for the building permit.
- Funding is by WPCLF Loans
 - Special Forms and Requirements
 - Davis - Bacon Prevailing Wage Rates

KEY MILESTONES

- Additional Site Visits on December 13, 2013 & December 20, 2013 at 9:00 A.M. EST
- Bid Opening – December 31, 2013
- Loan Award Meeting – February 27, 2014
- The Sludge Load Out Facility Substantial Completion deadline of December 1, 2014 was emphasized.
- Delete reference to agenda identifying Final Completion within 1,260 days and refer to Instruction to Bidders page ITB-16 specifying Substantial Completion 1,280 days from Notice to Proceed.
- One Year Certification Period

INSTRUCTIONS TO BIDDERS

- Bid Submittal Items – Reviewed Proposal Sheets
- Bid Alternates
 - Alternate A-4 and A-5 were further explained. Bid Item 1 should include the base bid cost for the Instrumentation and Controls Package and Process Operation Software Modules and Personnel Training. Bid Alternate A-4 and A-5 is only to be an Add or Deduct to the base bid for using SCI, Inc or 360 Water, Inc as subcontractors due to them being identified as especially qualified contractors to perform the work due to significant prior history of working at the treatment plant.
- Bid Security
- Equipment Standards and Substitutions
 - CT Consultants is not reviewing “or equal” equipment or substitutions during bidding except for equipment designated as a Standard by the Owner. All substitutions to Equipment Standards shall be submitted for review 30 days prior to bids being due. For equipment that is not designated as a Standard, if after award of the contract, the successful Bidder proposed to designate equipment not named, Bidder shall submit proposed equipment in accordance with General Conditions Article 6.05 and Specification Section 01024- Substitutions and Specification 01061 – Shop Drawings and Submittals. This is also explained in Volume 1 on page SE-1 of the Contract Documents.

- Subcontracted Work Categories Form was emphasized for bid submittal; only the category of work is needed, not specific subcontractors.
- DBE/MBE Goals
 - Forms must be submitted with the Bid as explained in the Instruction to Bidders.
- Method of Award
- Document Interpretations
 - The appendix includes non-contract reference documents that were used during detailed design. The quotations for the equipment designated as Standards were provided for reference only. Technical Specifications shall take precedence regarding discrepancies in scope. Contractor shall be responsible negotiating specific terms and conditions accordingly.
 - The information in the Appendix can be relied upon for accuracy but not completeness.

CONTRACT TERMS AND CONDITIONS

- Contract Bond
- Modified EJCDC General Conditions
- Project Labor Agreement (PLA)
 - Canton's Law Department stressed the importance for the Contractors to become familiar with the City's PLA.
- Supplemental Submittals by Apparent Low Bidder

PROJECT DESCRIPTION

- Overall Project Presentation. The presentation is accessible for Plan Holders to review on CT's website: <http://www.ctconsultants.com/bidinfo/10182/>.
 - A presentation of the overall project was provided. An example phasing plan was presented for the following:
 - The Preliminary Treatment area which needs to be completed before the MBR system is installed.
 - The MBR sequence of construction which was intended to illustrate all of the components that need to be in plan before starting up the MBR system.

- Five (5) of the six (6) aeration trains must remain in service at all times which is why the schedule calls for one (1) MBR Train conversion at a time.
 - The “orange” abandoned chemical feed piping throughout the tunnels is to be removed complete. This is not shown on the drawings but the Contractor is to familiarize oneself with the tunnels to include removal of the piping complete in the base bid.
- MBR System Installation. The presentation made by OVIVO is accessible for Plan Holders to review on CT’s website: <http://www.ctconsultants.com/bidinfo/10182/>.

QUESTIONS

The following questions and answers were put forward:

- Q1 The OVIVO Scope of Supply in the Agreement needs clarified regarding piping by OVIVO.
- A1 OVIVO confirmed that their Scope of Supply includes piping, fasteners and supports inside the MBR Basins.
- Q2 What type of control system is Ovivo supplying?
- A2 Controls will be by Allen Bradley PLCs with Control Logics. Communications will be via Ethernet or fiber cable.
- Q3 What time of connections will be on Ovivo’s supplied piping?
- A3 Connections will be flanged on header and grooved in basins.

FACILITY TOUR

H:\2010\10182\PHASE\66 Bidding\Pre-Bid Meeting And Minutes\Pre-Bid Minutes.Doc

SIGN-IN SHEET

PRE-BID MEETING SIGN IN SHEET: CITY OF CANTON WATER RECLAMATION FACILITY PHOSPHORUS / TOTAL NITROGEN PROJECT CONTRACT NO. 26
 DATE: November 22, 2013

NAME	COMPANY (REPRESENTING)	ADDRESS	CITY	ZIP	PHONE#	EMAIL ADDRESS
Tracy S. Mills	WRF	3530 Canton Ave SE	CANTON	44709	330-481-3080	Tracy.mills@cantonline.gov
B.A. Bartos	Service Director					
Davey Shepler	Birdles & Eckle					D.SHEPLER@Bristol.com
Randy Aubliker	Purchasing					randy.aubliker@cantonline.gov
John Highman	Purchasing					john.highman@cantonline.gov
Joe Martuccio	Canton Law					
Conrad Mellar	Stark Co. Serv. Eng.					
DOUG HARRIS	WRF					doug.harris@cantonline.gov
JOE FORNACE	MECHANICAL					SDennis@Mechanical.com
Schmid Denning	"					
CRAIG CRESSLER	CANTON LAW Pkg					Craig.Cressler@CantonLaw.com

SIGN-IN SHEET

PRE-BID MEETING SIGN IN SHEET: CITY OF CANTON WATER RECLAMATION FACILITY PHOSPHORUS / TOTAL NITROGEN PROJECT CONTRACT NO. 26
 DATE: November 22, 2013

NAME	COMPANY (REPRESENTING)	ADDRESS	CITY	ZIP	PHONE#	EMAIL ADDRESS
Tim Blom	McHenry & Assoc	2000 Emory Rd	Waukesha WI	44124	(216) 292-4696	tblom@mckenryassociates.com
MARK PARLI	OVIVO	2404 RUTLAND DR	Austin	78758	512 894 6000	MARK.PARLI@OVIVO.COM
Dustin Hall	OVIVO	"	"	"	"	Dustin.Hall@ovivo.com
Ailua Dong	OVIVO	"	"	"	"	Ailua.Dong@ovivo.com
Mike Nash	Walsh Construction	3011 W GRAND BLVD DETROIT MI 48222	"	"	313-218-3428	mnash@walshgroup.com
Joe GIBERT	"	"	"	"	313-556-7185	jogibert@walshgroup.com
Mike Grahame	Sachs Elec. Co.	1566 Lorain Wilton Rd ATLANTA GA	St. Louis	"	313-218-7530	Agraham@SachsElec.com
Jesse Phillips	OVIVO Water	1506 Pinnery Ctr SE	Canton	44707	(512) 239-8669	jess.phillips@ovivo.com
Audrey D. Topowski	CT	8150 Sterling Court	Mentor	44060	440-951-9000	ATopowski@ctconsultants.com
RICK TSCHANZ	TSCHANZ CONSULTANTS	4155 SANDY CREEK RD CANTON OHIO	CANTON	44705	330-491-3200	RICKTSCHANZ@TSCHANZCONSULTANTS.COM
Jim Meola	CT	MENTOR	"	44060	440-951-9000	Jmeola@ctconsultants.com

SIGN-IN SHEET

PRE-BID MEETING SIGN IN SHEET: CITY OF CANTON WATER RECLAMATION FACILITY PHOSPHORUS / TOTAL NITROGEN PROJECT CONTRACT NO. 26
 DATE: November 22, 2013

NAME	COMPANY (REPRESENTING)	ADDRESS	CITY	ZIP	PHONE#	EMAIL ADDRESS
JERRY VACCHY	ABBOTT ELECTRIC	1735 ALLEN AVE SE	CANTON	44704	330-452-6601	jerryv@abbott-electric.com
JIM ABBOTT	"	"	"	"	"	jim@abbott-electric.com
EUGENE PENDERGAST	SCF	7995 KNOX S. HIGHWAY RD.	MARIETTA	44037	330-894-2202	eugene@echio.net
RICH STUMMER	DANNAN SUPERIOR	1476 W. MARKET ST.	AKRON	44313	330-906-3605	ASTUMMER@DANNANSUPERIOR.COM
TOM JACKSON	Green Lines Construction	2608 CANTON LAKES WAY HENRIKLET OH	HENRIKLET	44233	330-220-3108	tjackson@glc.com
STEVEN HILMEYER	FOSDICK & HILMEYER	309 VINE ST SUITE 50	CINCINNATI	45202	513-419-4207	seh@manofhennig.com
CRING FANNIE	JACKS GUSSOD	2460 PARKWAY CENTER WARREN, OH.	WARREN	44485	330-394-5280	CFANNIE@JACKSGUSSODCONSTRUCTORS.COM
LLOYD LAMBRIX	Walbridge	277 WOODWARD Detroit, MI 48226	Detroit	48226	313-442-1236	lambrix@walbridge.com
PAT COUGHENOUR	MEUG FORMWORK SYSTEM	2000 AIRPARK DR SPRINGFIELD OHIO	Springfield	45502	937-206-2860	pcoughenour@meugformwork.com
MATT BENNETT	SABOK CONSTRUCTION CO.	10245 BEECHVILLE RD BEECHVILLE OH 44141	BEECHVILLE	44141	1 800 705 5251	ESTIMATING@SABOKCONSTRUCTION.COM
TOM HATCH	GE	1275 N. GALE RD CLEVE OH 44112	CLEVE	44112	330-730-164	tom.hatch@ge.com

8150 Sterling Court
 Mentor, Ohio 44060
 phone: 440.951.9000
 fax: 440.951.7487
 www.ctconsultants.com



SIGN-IN SHEET

PRE-BID MEETING SIGN IN SHEET: CITY OF CANTON WATER RECLAMATION FACILITY PHOSPHORUS / TOTAL NITROGEN PROJECT CONTRACT NO. 26
 DATE: November 22, 2013

NAME	COMPANY (REPRESENTING)	ADDRESS	CITY	ZIP	PHONE#	EMAIL ADDRESS
JEFF HOLLBACK	KOKOSING CONSTRUCTION	6235 WESTERVILLE RD SUITE 200	WESTERVILLE	43081	614-212-5700	jch@kokosing.biz
John Kelly	PC Construction Co.	195 Tilley Dr S. Burlington, VT 05403	South Burlington VT	05403	802-651-1320	JKELLY@PCconstruction.com
Erica Croker	PC Construction Co.	193 Tilley Dr.	South Burlington VT	05403	802-651-1238	ECROKER@PCconstruction.com
Brett Burgett	Kokosing Construction Co.	6235 Westerville Road	Westerville OH	43081	740-622-1573	brettle.kokosing.biz
Kent Sabine	S.F.I. Inc.	8555 McCawp Rd Kensington, OH 44127	Kensington	44127	330-223-7022	KensingtonElectrical.net
Tom McDonald	Beaver	2000 Beaver Place Avenue Canton, OH 44706	Canton	44706	330-478-2151	tommcd@beaverconstructors.com
Chad Ratkovich	Beaver	"	"	"	"	chad.ratkovich@beaverescavating.com
Brent Tice	Tri-State Tool & Hardware	701 S. Elsworth Salem, Ohio 44460	Salem	44460	330-332-3300	brent@tristatetool.com
Tony Lococo	Daver & Assoc	1284 Southcenter #105 Cleveland OH 44124	Cleveland	44124	330-961-1087	tony@hibaner.com
JASON LYNKALD	MANBRIDGE	777 WESTERVILLE RD	DETROIT	48226	313-442-1457	jlynkald@manbridge.com
Steve Zizdel	"	"	"	"	"	szizdel@walbridge.com

8150 Sterling Court
 Mentor, Ohio 44060
 phone: 440.951.9000
 fax: 440.951.7487
 www.ctconsultants.com



SIGN-IN SHEET

PRE-BID MEETING SIGN IN SHEET: CITY OF CANTON WATER RECLAMATION FACILITY PHOSPHORUS / TOTAL NITROGEN PROJECT CONTRACT NO. 26
 DATE: November 22, 2013

NAME	COMPANY (REPRESENTING)	ADDRESS	CITY	ZIP	PHONE#	EMAIL ADDRESS
David Crinister	SHOOK	BRECKNELL		44141	1-800-703-8261	ESTIMATE@SHOOKCONSULTANTS.COM
Jerry Bryan Jr.	Rexel	30310 Emerald Valley Pkwy	Solon	44139	1-440-498-6286	jerry.bryanjr@brexelusa.com
JEFFERY V SCOTT	Kennont Const	700 Home Ave Akron, Ohio 44310	Akron	44310	330-762-9373	JScott@kennont.com
Ashley Williston Cousins	CT Consultants ll	8150 Sterling Ct Mentor, OH 44060 "	Mentor " "	44060 " "	440-530-2308 440-530-2255	awilliston@ctconsultants.com cousins@ctconsultants.com

8150 Sterling Court
 Mentor, Ohio 44060
 phone: 440.951.9000
 fax: 440.951.7487
 www.ctconsultants.com

