



THE CITY OF
CANTON
WILLIAM J. HEALY II, MAYOR

ENGINEERING DEPARTMENT

Civil/Traffic/Parking/Signal & Lighting/Sign & Pavement Marking

Daniel J. Moeglin, P.E., S.I., City Engineer

2436 30th St. NE/Canton OH 44705

PH 330 - 489-6900 / FAX 330 - 489-3337

February 24, 2012

ADDENDUM #2

TO: PROSPECTIVE BIDDERS

RE: WESTSIDE INTERCEPTOR REHABILITATION G.P. 1138

The attention of all Bidders on the above project, bids which shall be taken on February 28, 2012 is called to this Addendum # 2.

Make the following corrections to the Construction Contract & Specifications Booklets:

D). CHANGE the following paragraph in ITEM 54 MANHOLE REHABILITATION Page 61:

From:

3.3 Coating Product

- Coating product shall be applied to all interior surfaces to provide a permanent impermeable, high strength; monolithic lining for concrete structures that is sulfuric acid corrosion, abrasion and impact resistant.
- The approved lining systems are:
 - Raven 405 by Raven Lining Systems. Minimum total wet film thickness shall be 500 mils.
 - SpectraShield by SpectraShield Lining Systems. Minimum total wet film thickness shall be 125 mils.
- Coating product physical properties shall be substantiated through submittal of accredited third party testing results and shall be representative of the actual field applied product and cure mechanism(s) to be employed in the field.



THE CITY OF
CANTON
WILLIAM J. HEALY II, MAYOR

To:

3.3 Coating Product

- Coating product shall be applied to all interior surfaces to provide a permanent impermeable, high strength; monolithic lining for concrete structures that is sulfuric acid corrosion, abrasion and impact resistant.
- The approved lining systems are:
 - Raven 405 by Raven Lining Systems. Minimum total wet film thickness shall be **125** mils.
 - SpectraShield by SpectraShield Lining Systems. Minimum total wet film thickness shall be **500** mils.
- Coating product physical properties shall be substantiated through submittal of accredited third party testing results and shall be representative of the actual field applied product and cure mechanism(s) to be employed in the field.

- 2). Remove duplicate Appendix B, Appendix C and Appendix D located directly after Appendix A.



THE CITY OF
CANTON
WILLIAM J. HEALY II, MAYOR

Please sign this Addendum No. 2 at the bottom of this page as proof of receipt and RETURN
SAME WITH YOUR BID.

Thank you for your cooperation in this matter.

Respectfully,

Paul Wilson, P.E.
Sanitary Engineer

BIDDERS AUTHORIZED SIGNATURE DATE

NAME / TITLE (Printed or Typed)