
OFFICIAL ADDENDUM

Water Reclamation Facility (WRF) Boiler
Replacement Project

Bids Due July 18, 2013

The City of Canton WRF

The following items shall apply to the project in addition to the current technical specifications. This addendum shall become part of the official bid packet. Failure to acknowledge the addendum by returning it as part of your bid may result in your bid being disqualified.

Water Reclamation Facility (WRF) Boiler Replacement Project

1. The following boiler is considered as an “or approved equal”:

Manufacturer and Model Number: Bryan AB-200

2. Warranty for entire boiler system shall be a minimum of one year and shall include all parts and labor.
3. The existing boiler pump shall be replaced with a new pump per the approved boiler manufacturer’s recommendations.